



NOTE:  
All Surface Water and Wastewater sewer Pipes shall be protected with a concrete surround, with flexible joints filled with compressible material, where the depth from the road surface to the crown of the pipe is less than 1200mm.  
(See STD-WW-07 and STD-WW-08 on drawing no. 19074-P-501 for details of concrete surround to be used on both sewers.)

Note:  
All foul sewer construction details to comply with the following Irish Water Documents:  
'Recommendations for Site Development Works for Housing Areas' DoEHLG 1998

