



NOTE:
All Surface Water and Wastewater sewer Pipes shall be protected with a concrete surround, with flexible joints filled with compressible material, where the depth from the road surface to the crown of the pipe is less than 1200mm.
(See STD-WW-07 and STD-WW-08 on drawing no. 19074-P-501 for details of concrete surround to be used on both sewers.)

LEGEND
 Existing Ground Level
 Proposed Ground Level

Note:
All foul sewer construction details to comply with the following Irish Water Documents:
IW-CDS-5030-01 Wastewater Infrastructure Standard Details, July 2020, Revision 4,
IW-CDS-5030-03 Code of practice for Wastewater Infrastructure, July 2020, Revision 2.

ID	Issued for planning	CD-02-22	IR	MW
A	Issued for construction	22-03-24	IR	MW
Description	Title	Date	Rev	By

walsh
design
group